

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 412/D/SWA/NSA

Dated: 19/8/2025

It is certified that an inspection team headed by ALKA SINGH - CHEMIST

(Name of Officers with designation) from KANPUR NAGAR NIGAM PHED

inspected the NLK ACADEMY, BHAWANIPUR, MANDHANA, KANPUR

(Name & Address of the school) on 09/8/2025.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 302/SWA/CHEM..... dated 16/08/2025

of Public Health Laboratory KANPUR (PHED Lab) certified that the
NLK ACADEMY.....(Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt

This certificate is valid till ONE YEAR.

Signature with Seal:

Name: ALKA SINGH - अधिकारी

Designation:

Name & Address of the Office / Department: KANPUR NIGAM KANPUR

To NLK ACADEMY, KANPUR

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

65 |



NLK ACADEMY
Chasing dreams with Learning

Alka Singh

Principal



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the NLK ACADEMY, Bhawanipur, Mandhana
Sample taken from SUBMERSIBLE (R.O.) Kanpur
Date of sample Drawn 09/08/2025
Date of analysis 09/08/2025
Physical Character TRANSPARENT / ODORLESS
P. H. Value 7.64
Free Ammonia Parts per 1000000 NIL
Albuminoid Ammonia Part per 1000000 NIL
Oxygen absorbed from pot. Permanganate
in three hours at 37° C 0.00
Chloride Part per 1000000 16.00
Nitrates Parts per 1000000 NIL
Nitrates Parts per 1000000 NIL
Total solid part per 100000 290.00
Fixed solid Parts per 1000000 250.00
Volatils solid Parts per 100000 40.00
Appearance on ignition No Charring
Total hardness Parts per 1000000 144.00
Permanent hardness Parts per 1000000 110.00
Temporary hardness Parts per 1000000 26.00

Remarks :

POTABLE



NLK ACADEMY
Chasing dreams with Learning

Alka Singh

Principal

No. 382/2025 dated 16/08/2025

Copy forwarded for favour or information to


1) NLK Academy, Bhawanipur
Mandhana, Kanpur

ALKA SINGH
(Chemist)
Nagar Nigam Kanpur

Nagar Swachhata Adhikari
Nagar Nigam Kanpur

नगर निगम कानपुर

2) N.S.A. Kanpur Nagar Nigam



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from NLK ACADEMY, BHAWANIPUR, MANDHANA, KANPUR

Name & designation of the person collecting samples ALKA SINGH - CHEMIST

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count				Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS
		at 37.c in 48 hours	at room temp-rature in 72 hours	Quantity of water put in each tube No of tubes put up	50ML 1	10 ML 5	1 ML 5			
23/6/2025	SUGHERABLE	'ZERO'	'6'	—	NIL	NIL	NIL	'ZERO'	NIL	Good

Copy for Information Forwarded to (1) NLK Academy, Bhawanipur, Mandhana, Kanpur
(2) N.S.A. Kanpur Nagar Nigam



NLK ACADEMY
Chasirama with Learning

Alka Singh
Principal

Alka Singh
(Chemist)
Nagar Nigam Kanpur